

## NUMBER OF SAMPLES REQUIRED BY POPULATION GROUP

Population Served	Minimum number of samples per sampling period
25 to 2,500.....	2
2,501 to 3,300.....	3
3,301 to 4,100.....	4 (surface <u>pws</u> min.)
4,101 to 4,900.....	5
4,901 to 5,800.....	6
5,801 to 6,700.....	7
6,701 to 7,600.....	8
7,601 to 8,500.....	9
8,501 to 12,900.....	10
12,901 to 17,200.....	15
17,201 to 21,500.....	20
21,501 to 25,000.....	25
25,001 to 33,000.....	30
33,001 to 41,000.....	40
41,001 to 50,000.....	50
50,001 to 59,000.....	60
59,001 to 70,000.....	70
70,001 to 83,000.....	80
83,001 to 96,000.....	90
96,001 to 130,000.....	100
130,001 to 220,000.....	120
220,001 to 320,000.....	150
320,001 to 450,000.....	180

For each additional 150,000 in population, an additional 30 water samples shall be analyzed per sampling period.