

SAMPLE REPORTS

TS-1000

A N GROSS 7	B O NET 8	C P LEVEL 9	←← CANCEL CANCEL
D Q ULLGE 4	E R WATER 5	F S TEMP 6	G T UP +/-
H U CLOCK 1	I V ALARM 2	J W REPORT 3	K X DOWN SPACE
ACK SHIFT	L Y TEST 0	M Z SETUP	ENTER

Reports Available

- | | |
|------------------------------------|-----------------------|
| 1. Inventory | 2. Reconciliation |
| 3. Delivery | 4. Delivery History |
| 5. Leak Test | 6. Leak Time Estimate |
| 7. Alarm | 8. Alarm History |
| 9. Line Test | 10. Line Test History |
| 11. Alarm Status and Configuration | |
| 12. System Configuration | |
| 13. Tank Configuration | |

Console Keypad

1. To Print Desired Report

- a. Press **REPORT** key
- b. Press **UP** or **DOWN** until desired report
- c. Press **ENTER**
- d. If prompted, enter tank number or **0** for all tanks
- e. Press **ENTER** to print report

JOHNS GAS STOP 111 OAK ST. BIDDEFORD, ME 04805 SITE # 001	
7/25/1990 02:09 PM INVENTORY REPORT	
TANK NO. 1	0000 GAL
	UNLEADED REG
GROSS	5051.7 GAL
NET	5024.7 GAL
PROD LEVEL	57.918 IN
ULLAGE	2963.4 GAL
TEMPERATURE	67.606 F
WATER LEVEL	0.584 IN
WATER VOL	6.4 GAL

Inventory Report

JOHNS GAS STOP 111 OAK ST. BIDDEFORD, ME 04805 SITE # 001	
7/25/1990 02:11 PM LEAK TEST REPORT	
TANK NO. 1	0000 GAL
	UNLEADED REG
THRESHOLD	0.20 GAL/HR
CONFIDENCE LEVEL	95.0%
TEST STARTED	12:00 AM
TEST STARTED	07/25/1990
LAST DELIVERY	6:15 AM
LAST DELIVERY	07/24/1990
% GROSS CAPACITY	73.60
BEGIN GROSS	5983.8 GAL
BEGIN NET	5069.2 GAL
BEGIN LEVEL	66.311 IN
BEGIN TEMP	68.334 F
BEGIN WATER	6.5 GAL
BEGIN WATER	0.584 IN
END TIME	1:59 AM
END DATE	07/25/1990
END GROSS	5983.4 GAL
END NET	5069.3 GAL
END LEVEL	66.307 IN
END TEMP	68.219 F
END WATER	6.5 GAL
END WATER	0.584 IN
HOURLY DATA	
TIME	DEG F GAL
1:00 AM	68.276 5875.68
1:59 AM	68.219 5875.72
SLOPE	0.04 GAL/HR
SLOPE LOW	0.04 GAL/HR
SLOPE HIGH	0.04 GAL/HR
TEST RESULTS	PASSED

Leak Test Report

SAMPLE REPORTS

TS-1000

(cont)

JOHNS GAS STOP
111 OAK ST.
BIDDEFORD, ME 04805
SITE # 001

7/24/1990 04:39 AM
ALARM REPORT

7/24/1990 04:38 AM
THEFT
TANK NO. 1

Alarm Report

JOHNS GAS STOP
111 OAK ST.
BIDDEFORD, ME 04805
SITE # 001

7/25/1990 02:12 PM
ALARM HISTORY REPORT

7/11/1990 05:48 PM
POWER UP

7/11/1990 05:48 PM
OVERFILL
TANK NO. 1

7/23/1990 03:38 PM
POWER UP

7/23/1990 06:17 PM
LOW LIMIT
TANK NO. 1

7/25/1990 05:51 AM
THEFT
TANK NO. 1

Alarm History Report

JOHNS GAS STOP
111 OAK ST.
BIDDEFORD, ME 04805
SITE # 001

7/25/1990 02:10 PM
DELIVERY REPORT

TANK NO. 1 0000 GAL
UNLEADED REG

BEGIN TIME 6:15 AM
BEGIN DATE 07/24/1990
BEGIN GROSS 799.3 GAL
BEGIN NET 796.7 GAL
BEGIN LEVEL 15.065 IN
BEGIN WATER 0.571 IN
BEGIN WATER 6.2 GAL
BEGIN TEMP 64.501 F
END TIME 6:37 AM
END DATE 07/24/1990
END GROSS 6722.8 GAL
END NET 6676.5 GAL
END LEVEL 75.066 IN
END WATER 0.581 IN
END WATER 6.4 GAL
END TEMP 69.708 F
GROSS DEL 5923.5 GAL
NET DEL 5879.8 GAL

Delivery Report

JOHNS GAS STOP
111 OAK ST.
BIDDEFORD, ME 04805
SITE # 001

7/25/1990 02:14 PM
DELIVERY HISTORY REPORT

TANK NO. 1 0000 GAL
UNLEADED REG

BEGIN TIME 6:15 AM
BEGIN DATE 07/24/1990
BEGIN GROSS 799.3 GAL
BEGIN NET 796.7 GAL
BEGIN LEVEL 15.065 IN
BEGIN WATER 0.571 IN
BEGIN WATER 6.2 GAL
BEGIN TEMP 64.601 F
END TIME 6:37 AM
END DATE 07/24/1990
END GROSS 6722.8 GAL
END NET 6676.5 GAL
END LEVEL 75.066 IN
END WATER 0.581 IN
END WATER 6.4 GAL
END TEMP 69.708 F
GROSS DEL 5923.5 GAL
NET DEL 5879.8 GAL

Delivery History Report

BEGIN TIME 6:13 AM
BEGIN DATE 08/24/1990
BEGIN GROSS 1657.0 GAL
BEGIN NET 1658.0 GAL
BEGIN LEVEL 24.952 IN
BEGIN WATER 0.054 IN
BEGIN WATER 0.0 GAL
BEGIN TEMP 66.733 F
END TIME 6:21 AM
END DATE 08/24/1990
END GROSS 3190.3 GAL
END NET 3171.5 GAL
END LEVEL 40.026 IN
END WATER 0.050 IN
END WATER 0.0 GAL
END TEMP 68.417 F
GROSS DEL 1532.4 GAL
NET DEL 1521.5 GAL