

SAMPLE REPORTS RLM 5000

1. Inventory Report (non-temp comp)

- a. Press **RPRT** key
- b. Press **UP** or **DN** key till "Inventory"
- c. Press **ENTER** key
- d. Press **1 - 8** for desired tank or **0** for all tanks
- e. Press **ENTER** key

```

RED JACKET TECH LINE
1-800-468-7867
MISSION: KS
SITE #

1/1/1964      12:14 AM
INVENTORY REPORT
  
```

```
TANK NO. 1      GAL
```

```

GROSS      2285.3 GAL
NET        2259.9 GAL
PROD LEVEL 36.821 IN
ULLAGE     3682.6 GAL
TEMPERATURE 75.737 F
WATER LEVEL 1.963 IN
WATER VOL  45.0 GAL
  
```

2. Reconciliation Report (temp comp)

- a. Press **RPRT** key
- b. Press **UP** or **DN** key till "Reconcil"
- c. Press **ENTER** key
- d. Press **1 - 8** for desired tank or **0** for all tanks
- e. Press **ENTER** key

```

RED JACKET TECH LINE
1-800-468-7867
MISSION, KS
SITE #
  
```

```
1/7/1964      10:50 PM
LEAK TEST REPORT
```

```
TANK NO. 1      GAL
```

```

THRESHOLD  0.20 GAL/HR
CONFIDENCE LEVEL 95.0%
TEST STARTED 3:42 AM
TEST STARTED 01/03/1964
% GROSS CAPACITY 39.90
BEGIN GROSS 2399.4 GAL
BEGIN NET 2371.2 GAL
BEGIN LEVEL 37.802 IN
BEGIN TEMP 76.640 F
BEGIN WATER 16.1 GAL
BEGIN WATER 0.738 IN
END TIME 5:22 AM
END DATE 01/03/1964
END GROSS 2399.4 GAL
END NET 2372.0 GAL
END LEVEL 37.802 IN
END TEMP 76.209 F
END WATER 16.1 GAL
END WATER 0.738 IN
  
```

3. Delivery Report

- a. Press **RPRT** key
- b. Press **UP** or **DN** key till "Delivery"
- c. Press **ENTER** key
- d. Press **1 - 8** for desired tank or **0** for all tanks
- e. Press **ENTER** key

4. Delivery History Report (if programmed)

- a. Press **RPRT** key
- b. Press **UP** or **DN** key till "Del Hist"
- c. Press **ENTER** key
- d. Press **1 - 8** for desired tank or **0** for all tanks
- e. Press **ENTER** key

5. Leak Test Report

- a. Press **RPRT** key
- b. Press **UP** or **DN** key till "Leak"
- c. Press **ENTER** key
- d. Press **1 - 8** for desired tank or **0** for all tanks
- e. Press **ENTER** key

HOURLY DATA

```

TIME      DEG F  GAL
4:42 AM  76.350  2387.88
  
```

```

SLOPE      0.54 GAL/HR
SLOPE LOW  0.54 GAL/HR
SLOPE HIGH 0.55 GAL/HR
TEST RESULTS      PASSED
  
```

SAMPLE REPORTS

RLM 5000

(Cont)

6. Leak Estimate Report (length of test)

- a. Press **RPRT** key
- b. Press **UP** or **DN** key till "Leak Est"
- c. Press **ENTER** key
- d. Press **1 - 8** for desired tank or **0** for all tanks
- e. Press **ENTER** key

RED JACKET TECH LINE
1-800-468-7867
MISSION, KS
SITE #
1/1/1964 12:02 AM
LEAK ESTIMATE REPORT

TANK NO. 1 GAL

THRESHOLD 0.10 GAL/HR
CONFIDENCE LEVEL 97.5%
PERCENT CAPACITY 38.75
GROSS 2285.3 GAL
NET 2259.7 GAL
LEVEL 36.821 IN
TEMP 75.867 F
WATER VOL 45.0 GAL
WATER LEVEL 1.964 IN
EST TIME 3 HRS 20 MIN

7. Alarm History Report

- a. Press **RPRT** key
- b. Press **UP** or **DN** key till "Alarm Hist"
- c. Press **ENTER** key
- d. Press **1 - 8** for desired tank or **0** for all tanks
- e. Press **ENTER** key; last 50 alarms

8. Alarm Status Report (current alarms)

- a. Press **RPRT** key
- b. Press **UP** or **DN** key till "Alarm Stat"
- c. Press **ENTER** key
- d. Press **1 - 8** for desired tank or **0** for all tanks
- e. Press **ENTER** key

RED JACKET TECH LINE
1-800-468-7867
MISSION, KS
SITE #
1/1/1964 12:05 AM
ALARM STATUS REPORT

TANK NO. 1 GAL

HIGH LIMIT
ACTIVE
HIGH LIMIT 0.000 IN
LOW LIMIT
CLEARED
LOW LIMIT 0.0 GAL

9. System Setup Report

- a. Press **RPRT** key
- b. Press **UP** or **DN** key till "Setup"
- c. Press **ENTER** key
- d. Press **1 - 8** for desired tank or **0** for all tanks
- e. Press **ENTER** key

WATER LIMIT
ACTIVE
WATER LIMIT 0.000 IN
LEAK
LEAK LIMIT 2.0 G/H
THEFT
THEFT LIMIT 10.0 GAL

10. Tank Setup Report

- a. Press **RPRT** key
- b. Press **UP** or **DN** key till "Tank set up"
- c. Press **ENTER** key
- d. Press **1 - 8** for desired tank or **0** for all tanks
- e. Press **ENTER** key